



PUBLIC NOTICE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
FAILURE TO MONITOR

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Lake Shore Water Association

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2024 we failed to monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, the required sampling frequency, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
HAA5's	1 / Quarter	1	June 9-15, 2024	June 11, 2024
TTHM's	1 / Quarter	1	June 9-15, 2024	June 11, 2024
Chlorine	1/Week	3	Weekly, between 5/5/24 and 6/1/24	Weekly, between 5/5/24 and 6/1/24


What happened? What was done? When will it be resolved?

All samples were taken and taken ONTIME. However, the HAA5 and TTHM locations were switched, each grabbed from the others sample point. This was corrected in the 3rd quarter sampling. The chlorine samples were also done when needed, but were reported to DEP's system late, so it triggered a violation as late reporting.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Julio Pazmino at 814-572-0139.

Certified by:

Signature: 

Date: 5/19/25

Print Name and Title: Julio Pazmino (Certified Operator)

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: _____

PWS ID#: 6250039

Date distributed: _____